RESERVE BOOK ROOM — NEW STACKS — EXISTING STACKS — NEW STACKS — EXISTING STACKS — NEW STACKS — EXISTING STACKS — NEW STACKS — EXISTING STACKS

REMOVE & RELOCATE RAD.

F.D.

7S x 19 UP
7S x 19 DN.

40 x 30 UP

LOBBY

30 x 24 DN.

LIBRARIAN'S OFFICE

30 x 14 DN. & UNDER 12" DIA.

UNDER THIRD LEVEL

BELOW BEAM

FAIRWAY HALL

12 x 12 UP

84 x 14 UP
84 x 14 DN.

30 x 22

19 x 14

19 x 11

30 x 22 DN.

30 x 17 DN.

17 x 11

UNDER S.B.M.

84 x 14 UP
48 x 14 DN.

12 x 12 UP

5 - 12 DN
30 x 18 UP

REFERENCE AND NEWS ROOM

CENTRAL PLANT

FIRE DAMPERS TO BE INSTALLED WHERE INDICATED

DUCTS ARE TO BE INSTALLED UNDER EXISTING BEAMS — No BEAMS

PARTIAL PLAN STACKS THIRD LEVEL
SCALE 1/8" = 1'-0"

PARTIAL PLAN STACKS SECOND LEVEL
SCALE 1/8" = 1'-0"

PARTIAL PLAN STACKS FIRST LEVEL
SCALE 1/8" = 1'-0"

24" ø MANHOLE W/ C.I. COVER

15'-4

4'

1½"

15'-0"

1½" COND.

4" STM.

DRIP

ANCHOR

2'-0"

8" CHANNEL SET IN CONC.

PLAN

CHK V.

1½" COND.
4" STM. MAIN

S4 F.I.T. TRAP

SCHEMATIC - MANHOLE PIPING

LEGEND

CHILLED WATER SUPPLY
CHILLED WATER RETURN
CONDENSER SUPPLY
CONDENSER RETURN
GAS
BRAKING
DRAIN
GATE VALVE
GLOBE VALVE
CHECK VALVE
CONTROL VALVE
STRAINER
THERMOMETER
PRESSURE GAGE
DIRECTION OF FLOW
DIRECTION OF PITCH
AUTOMATIC AIR VENT
THERMOSTAT
FIRE DAMPER

F.D.

CHK V.

6" CS

EXPANSION TANK

SUPPLIED PER WATER BOTTOM PUMP MFG'S SPEC

CHK V.

6" CS

CONC. BASE

SHUT-OFF V.

DRAIN V.

CONC. FOOTING

4" STEAM
1½" COND.

EXPANSION LOOP

UNDERGROUND CONDUIT

ANCHOR PLATE AT MITERED ELBOW: 4.5 W x 5' L x 6.5 DEEP CONC. ANCHORAGE

DIRT LEG

NEW MANHOLE DETAILS
NO SCALE

NEW MANHOLE
SEE DETAIL

4'-6" MIN. DEPTH OF COVER

5' MIN. DEPTH OF COVER

1½" COND
4" STM. - DN.

4" ø

TOWER PUMP

COOLING TOWER

ELIMINATOR WALL

6" CS & 4" CW TO WALL VENT TO EQUIP. RM.

MAKE VALVED COUNTER NEAREST WATERLINE

TOWER & PUMP DETAIL
NO SCALE

1½" COND. LINE

2" CALCIUM SILICATE INS. ON STM. LINES IN CONDUIT

4" STM. LINE

15" ø R/C WIL. HEL-COR INSULATED PIPE UNIT

TRENCH

SECTION "A-A"
NO SCALE

EXISTING MANIFOLD

BLDG. STM.

STM. MAIN

5' MIN. DEPTH OF COVER
TAP 4" ø S.S. (FOR STM.) OFF MAIN VALVED, CONNECT 1½" TO CONDENSATE RET. - VALVED. ANCHOR BOTH LINES

EXISTING MANHOLE

RESEARCH

2 - 24 x 12 S-1
240 S.A.

2 - 20 x 8
250 S.A.

BOOKS & DOCUMENTS

2 - 20 x 10 S-1
545 S.A.

UNDER B.M.

30 x 24 UP

30 x 14

30 x 12

18 x 10

18 x 10 DN TRANS TO 13 x 10

BELOW B.M.

13 x 10

2 - 20 x 8 S-1
570 S.F.

CHILDRENS READING ROOM

UNDER FL.

LOBBY

ENTRANCE

2 - 20 x 8 S-1
570 S.F.

18 x 8 S-3
570

48 x 8 S-3
650

HALL

SERIALS DIVISION

2 - 20 x 8 S-1
570 S.F.

2 - 20 x 8 S-1
570 S.F.

2 - 20 x 8 S-1
570 S.F.